

## TAMBARAM FIRE & RESCUE SERVICES STATION

No: 188/ 2020  
RC No: 841/ V /2020

DATE: 21.12.2020

### NO OBJECTION CERTIFICATE


**SUBJECT:** Fire And Rescue Services-Tambaram - NOC To Erect A School Building / Issue School Recognition - Reg.

**NOTICE:** 1) Govt. Order No:122-School Education (2) Dept. Day 14.09.2004  
2) Govt. Order No: 123-School Education (2) Dept Day 14.09.2004  
Application received from **The Correspondent** .

As per the Govt. Order and the application, **SRI SATHYA SAI INSTITUTE OF EDU CARE** situated at **No.10,Gandhi Street, Fathima Nagar,Nemilichery,Chromepet,Chennai-44**. was inspected by the Station Officer Mr. A.Fatheeh (18.12.2020). There is **No Objection** from the Dept. Of Fire And Rescue Services a School building at this place or to issue School Recognition.

#### CONDITIONS:

- 1) This NOC Is Valid For One Year From The Date Of Issue.
- 2) All The Extinguishers Have To Be Recharged And Maintained Periodically As Per Code Practice In 2190/1992.
- 3) Fire & Safety System/ Arrangement Have To Be Provided In Accordance With The Requirement Of NBC Part Iv Fire And Life Safety 2005.



*[Signature]*  
21/12/2020  
**STATION OFFICER**  
**FIRE AND RESCUE SERVICE**  
TAMBARAM STATION, CHENNAI-600 047.

To:

**The Correspondent,**  
**SRI SATHYA SAI INSTITUTE OF EDU CARE,**  
**No. 10,Gandhi Street, Fathima Nagar,**  
**Nemilichery,Chromepet,Chennai-44**

Copy : District Officer, Chennai South District.

*[Signature]*  
**K. Sai Gouzie**

**PRINCIPAL**  
**Sri Sathya Sai Institute of Educare,**  
**Nemilichery, Chrompet,**  
**Chennai - 600 044.**

*[Signature]*

**CORRESPONDENT**  
**SRI SATHYA SAI INSTITUTE OF EDUCARE.**  
**Nemilichery, Chromepet,**  
**Chennai - 600 044.**

*[Signature]*

**DIRECTOR**  
**SRI SATHYA SAI INSTITUTE OF EDUCARE**  
**Nemilichery, Chromepet,**  
**Chennai - 600 044.**